

SAP Appendix Q Testing Results
Central mechanical supply and exhaust ventilation system
packages with heat recovery used in a single dwelling

Brand Name		Vent Axia
Model		Sentinel 200
Model Qualifier (if applicable)		
Current Manufacturer and Contact Details	Name	Vent Axia Ltd
	Address	Fleming Way Crawley West Sussex RH10 9YX
	Telephone	01293 441535
	Website	www.vent-axia.co.uk
Original Manufacturer (if different)		
First Year of Manufacture		2009
Last Year of Manufacture		
Testing Body		BRE
Date of test		30/03/09
Serial Number of Product Tested		23 09 0056
MVHR to outside grille duct types and size		150 & 125mm diameter rigid plastic & 200mm rectangular rigid plastic
Duct types and sizes used for supply and exhaust		150 & 125mm diameter rigid plastic & 200mm rectangular rigid plastic

Results of leakage tests

Table Q1

Internal	Pass
External	Pass

Results for SAP calculations (at minimum flow rate condition)

This product has only been tested with rigid ductwork and the data are not applicable for SAP calculations if installed with flexible ductwork.

Table Q2 – Systems with rigid ductwork only

Exhaust terminal configuration	Fan speed setting	Specific fan power (W/l/s)	Heat exchange efficiency (%)	Energy Saving Trust Best Practice Performance Compliant
Kitchen + 1 additional wet rooms	Supply 14 l/s Exhaust 15 l/s	0.72	85	Yes
Kitchen + 2 additional wet rooms	Supply 18 l/s Exhaust 19 l/s	0.74	85	Yes
Kitchen + 3 additional wet rooms	Supply 22 l/s Exhaust 23 l/s	0.83	84	No
Kitchen + 4 additional wet rooms	Supply 25 l/s Exhaust 26 l/s	0.92	83	No

These figures are entered into either:

- (a) In the case of SAP software amended to SAP 2005 version 9.81 allowing direct entry of MVHR data, the SAP software, or
- (b) In the case of SAP software amended to SAP 2005 version 9.81 not allowing direct entry of MVHR data, the SAP Q MVHR Calculation Spreadsheet v9.81 and the results from the spreadsheet into the Special Features part of the SAP 9.81 software, or
- (c) In the case of SAP software to SAP 2005 version 9.80 , the SAP Q MVHR Calculation Spreadsheet v9.80 and the results from the spreadsheet into the Special Features part of the SAP 9.80 software. They must **NOT** be entered directly into SAP 2005 version 9.80 software

Table Q3 – Systems with flexible ductwork only

Exhaust terminal configuration	Fan speed setting	Specific fan power (W/l/s)	Heat exchange efficiency (%)	Energy Saving Trust Best Practice Performance Compliant
Kitchen + 1 additional wet room	N/A	N/A	N/A	N/A

Results for Approved Document F (at maximum flow rate condition)

Table Q4

Exhaust terminal configuration	Fan speed setting	Total exhaust flow rate (l/s)	Total supply flow rate (l/s)
Kitchen + 1 additional wet rooms	Supply 14 l/s Exhaust 15 l/s	15.0	15.0
Kitchen + 2 additional wet rooms	Supply 18 l/s Exhaust 19 l/s	21.0	21.0
Kitchen + 3 additional wet rooms	Supply 22 l/s Exhaust 23 l/s	27.0	27.0
Kitchen + 4 additional wet rooms	Supply 25 l/s Exhaust 26 l/s	33.0	33.0

Comments

Only figures from Table Q2 or Table Q3, not both, should be used with the SAP Q Calculation Spreadsheet for this technology type.

Table Q4 results are only applicable for Approved Document F requirements.